



# BROCKPORT

## Central School District

**Business Offices** • 40 Allen Street, Brockport, New York 14420 – 2296 • Phone (585) 637-1820 • Fax: (585) 637-1829

**Darrin N. Winkley**

*Assistant Superintendent for Business*

### **Brockport Central School District Lead Remediation - Action Plan – September 14, 2022** **Updated January 4, 2023**

In July of 2022 the Brockport Central School District contracted with Labella Associates to collect first draw samples from outlets of potential drinking water sources throughout five school buildings and 3 auxiliary buildings.

A total of 152 samples were taken district wide. Of those 152 samples, 15 were found to have lead levels above the action level of 15 PPB (Parts per Billion). 14 of the 15 were retested and results were below the action level and required no further action.

The one remaining outlet tested above 15 PPB in August 2022. This fixture in room 308 of the Ginther School has been taken out of service until a new fixture and piping can be installed. Once the replacement work is completed, the fixture will be retested.

<b>Building</b>	<b>Room #</b>	<b>Fixture</b>	<b>Action</b>
Ginther	308	Room 308 Water Fountain	Fixture removed from service until replacement fixture and piping can be installed and retesting of the fixture

Remediation measures to be taken at the location(s) and the fixture(s) will be retested and results posted.

- **Ginther School Room 308 Water Fountain** – Replace fixture and piping and retest was 5.45 PPB